



Somers Fire & Rescue Department
Captain Joe Scruggs, Fire Inspector
P.O. Box 197, Somers, WI 53171
jscruggs@somers.org
(262) 620-3285

FIRE APPARATUS SITE ACCESS

Access shall be provided around the perimeter of the site for all Fire Department apparatus, and must comply with the State of Wisconsin and the most current edition of the International Building Code adopted by The State of Wisconsin. A minimum wall-to-wall turning radius of 45'-0" shall be allowed for apparatus movement.

- A. All entrances from public streets, as well as road and driveways around the proposed building, must be a minimum of 20 feet wide.
- B. All exterior exit pathways as well as access to the Fire Pump Room shall have a hard surface, leading to a hard surface.
- C. An exterior personnel door shall be located in close proximity to each fire sprinkler riser.
- D. Each door must access from the outside.